



- General Notes:**
1. This is a performance drawing only which should be used for guidance and pricing only.
 2. Construction/working drawings are the sole responsibility of the contractor.
 3. This drawing is to be read in conjunction with all relevant architects drawings, indicative survey drawings and mechanical & electrical specifications and schedules.
 4. Do not scale. This drawing is representative only.
 5. Electrical services to be co-ordinated with all other trades, and to be agreed on site prior to installation, additional costs incurred by the contractor due to the lack of co-ordination, will not be entertained.
 6. The final coordinated location of all services and fittings must be agreed in advance with the architect and engineers.
 7. The consulting engineer shall be notified by the contractor of any errors only, or omissions on the drawings.
 8. Exact location of all plant, equipment and penetrations are the responsibility of the contractor who shall co-ordinate the installation with other trades.
 9. The contractor shall note that conduits are not shown. The contractor shall include for planning and co-ordination of the conduit installation.
 10. There shall be no more than ten luminaires per circuit.
 11. Tolerant circuits to be RCD protected.
 12. Fire cert drawings should be read in conjunction with this drawing.
 13. All elements of the lighting and emergency lighting installation shall be carried out in accordance with ET101:2008, IS3217:2013, contract specifications, schedules and manufacturers recommendations.
 14. All emergency lighting shall be on the DALI control system as shown.

- Symbols Reference:**
- New Luminaire
 - Existing Luminaire
 - Existing Wall Mounted Luminaire
 - + Lighting Column 10 metre
 - + Existing Lighting Column 10 metre
 - Public Lighting Draw PIT
 - Public Lighting Micro Pillar
 - ▲ ESB Mini Pillar
 - ESB LV Ducting
 - Public Lighting LV Ducting



P01	25.09.19	Issue For Planning	JC	RK
REV	DATE	AMENDMENT	DRN	CHK
Issued for Information				
axiseng consulting engineers		<small>21 Wood Street Upper Dunedin 9010 +64 3 479 0004 +64 3 479 0104 info@axiseng.co.nz www.axiseng.co.nz</small>		
Client:				
Architect: John Fleming Architects				
Project: Citywest Development Site Masterplan Public Lighting Lux Levels				
Dwg. No: BTR-AXE-XX-DR-E-60102				
Job No: 19056	Scale: 1:500 @ A0	Sheet: S2	Revision: P01	
<small>This drawing is the property of axiseng. Copyright is reserved by axiseng and the drawing shall not be copied, reproduced or otherwise used without the consent of axiseng.</small>				